





















| NO GROUP | UKURAN KABEL |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  |  | LOAD WATT | | |
|----------|--------------------------------------|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|--|-----------|--------|--------|
| | | HANGING LED STRIP 15W/M | INDIRECT LED STRIP 15W/M | TRACK LAMP LED 2x5 W | HANGING SPOTLIGHT 15 W | DOWNLIGHT 20 W | INDIRECT FLOOR LED STRIP 15W/M | FLOOR UPLIGHT 10 W | WALL LAMP INDIRECT STRIP 15W/M | DN LED OUTBOW 10W | DN LED OUTBOW 20W | TKO LED 2x20W | TKO LED 1x20W | TKO LED 1x20W +BATTERY | DN LED 15W+NB | EXIT LAMP LED 3W+NB | SK 16A, 1ø 200W | SK 16A, 1ø 200W (TIPE MEJA) | SK 16A, 1ø 300W (TIPE MEJA) | SK 16A, 1ø 450W (TIPE MEJA) | SK 16A, 1ø 1.500W | R | S | T |
| 1.K | NYM 3Cx2,5 mm2 PVC HI COND. ø20mm | | | | | | | | | | | | | | | | 4 | 5 | | | | | | |
| 2.K | | | | | | | | | | | | | | | | | | 6 | | | | 1200 | | |
| 3.K | | | | | | | | | | | | | | | | | 1 | 6 | | | | | | 1400 |
| 4.K | | | | | | | | | | | | | | | | | | | 7 | | | | | 1400 |
| 5.K | | | | | | | | | | | | | | | | | | | 8 | | | | 1600 | |
| | CADANGAN | | | | | | | | | | | | | | | | | | | | | | | |
| 6.K | NYM 3Cx2,5 mm2 PVC HI COND. ø20mm | | | | | | | | | | | | | | | | | | 5 | | | | | 1500 |
| 7.K | | | | | | | | | | | | | | | | | | | 6 | | | 1800 | | |
| 8.K | | | | | | | | | | | | | | | | | | | 6 | | | | 1800 | |
| 9.K | | | | | | | | | | | | | | | | | | | 6 | | | | | 1800 |
| 10.K | | | | | | | | | | | | | | | | | | | 6 | | | 1800 | | |
| 11.K | | | | | | | | | | | | | | | | | | 3 | 2 | | | | 1800 | |
| 12.K | | | | | | | | | | | | | | | | | 4 | | 2 | | | | | 1700 |
| 13.K | | | | | | | | | | | | | | | | | 7 | | | | | 1600 | | |
| 14.K | | | | | | | | | | | | | | | | | 1 | | | | | | 1500 | |
| 15.K | | | | | | | | | | | | | | | | | 2 | | | | | | | 2000 |
| 16.K | | | | | | | | | | | | | | | | | | | | 1 | | 1500 | | |
| 17.K | | | | | | | | | | | | | | | | | | | | 1 | | | 1500 | |
| | CADANGAN | | | | | | | | | | | | | | | | | | | | | | | |
| 1.P | NYM 4Cx2,5 mm2 PVC HI COND. ø20mm | | | | | | | | | | | | | | 8 | 3 | | | | | | | | 129 |
| 2.P | NYM 3Cx2,5 mm2 PVC HI COND. ø20mm | | 23 | 7 | | 7 | | | 5,4 | | 1 | | | | | | | | | | | 665 | | |
| 3.P | | | | 14 | | 6 | | | | | | | | | | | | | | | | | 260 | |
| 4.P | | 28 | 16 | | | | 26 | | | | | | | | | | | | | | | | | 1050 |
| 5.P | | | | | | | | 6 | | | | | | | | | | | | | | 60 | | |
| 6.P | | | 23 | 4 | | 6 | | | 14 | | | | | | | | | | | | | | 715 | |
| 7.P | | | 52 | | 4 | 11 | | | 9 | | | | | | | | | | | | | | | 1195 |
| 8.P | | | | | | 11 | | | 22 | 6 | | | 1 | 2 | | | | | | | | 670 | | |
| 9.P | | | 17 | | | 4 | | | | | 9 | | | | | | | | | | | | 515 | |
| 10.P | | | | | | 9 | | | | | 6 | | | | | | | | | | | | | 300 |
| 11.P | | | 35 | | | 10 | | | | | | | | | | | | | | | | 725 | | |
| 12.P | | | 12 | | | 7 | | | | | | | | | | | | | | | | | 320 | |
| | CADANGAN | | | | | | | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | | | | | | | |
| | TOTAL | 28 | 178 | 25 | 4 | 71 | 26 | 6 | 51 | 6 | 16 | | 1 | 2 | 8 | 3 | 19 | 32 | 32 | 4 | 2 | 11.620 | 10.210 | 12.474 |
| | | | | | | | | | | | | | | | | | | | | | | 34.304 W | | |

SPECIFICATION AND LINE CABLE BY BAS
FROM BMS FOR CONTROLLED START/STOP CIRCUIT BREAKER
FROM BAS FOR INCOMING PANEL MONITORING STATUS

OWNER/CLIENT

APPROVED : .../.../...

(signed)
..... (name)
..... (position)
..... (Dep./Div.)

PROJECT
BPDP
KELAPA SAWIT
Jl. Medan Merdeka Tim, RT.7/RW.1, Gambir,
Kec. Gambir, Kota Jakarta Pusat, Daerah
Khusus Ibukota Jakarta 10110

INTERIOR DESIGN CONSULTANT
PT. MADEA AGKASAMA
Jl. Hati Suci No. 4 Gd. Sakura Lt. 2 Room 201
Kel. Kampung Bali, Kec. Tanah Abang, Jakarta Pusat
Telp. 021 - 2303483, Fax. 021 - 2303483
APPROVED : //

MEP CONSULTANT

PT. DUTA PRATAMA ENGINEERING
MECHANICAL & ELECTRICAL ENGINEER
Rukan Taman Meruya Blok M No. 37, J. Bala Mula No. 1
Meruya Utara Kembangan -- Jakarta Barat 11620
Phone : 021-5845546, 5845547, 5845556, Fax : 021-58474531
Email : dpape.me@gmail.com, pt.dpa.me@yahoo.com

DRAWING TITLE
DIAGRAM PANEL
PL-L2
SCALE : NTS
ALL MEASUREMENT MUST BE CHECKED AT BY SITE
BY THE CONTRACTORS AND ANY DIFFERENCES
REPORTED/INITIATED TO THE DESIGNER FOR
CLARIFICATION BEFORE PROCEEDING.

| | |
|-----|-----------------|
| ... | .../.../... |
| ... | .../.../... |
| ... | .../.../... |
| ... | .../.../... |
| ... | .../.../... |
| # | REVISION : DATE |

DRAWN
Sangaji
DATE : 15/05/24
CHECKED
Jefri
DATE : 15/05/24
DRAWING FOR
TENDER
DATE : 2024/05/10